

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:11 pm

PWS ID: UTAH29014 **Name:** PLEASANT VIEW CULINARY WATER

Legal Contact PLEASANT VIEW CULNRY WTR
FRED CLARENCE HELLSTROM

Rating: Approved

Rating Date: 11/29/1988

Address: 520 W ELBERTA DR
OGDEN, UT 84414

Activity Status: Active

Phone Number:

City Served (Area):

County: WEBER COUNTY

System Type: Community

Last Inv Update: 07/18/2011

Avg Daily Prod:

Activity Status Cd: Active

Last Snty Srv Dt: 10/23/2007

Total Dsgn Cap:

Population: 6,000

Surveyor: LAURA SHOEMAKER

Total Emerg Cap:

Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	HELLSTROM, FRED CLARENCE		801-782-8529	801-782-5457	fhellstrom@pleasantviewcity

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	1,750
			1,750 Total Svc Connections

Storage

Total Storage: 2,040,000 GAL **Number of Units:** 6 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST006	JESSE CREEK RESERVOIR	Ground	800,000 GAL	Concrete		A	NO
ST003	ALDER #1	Ground	500,000 GAL	Concrete		A	
ST004	ALDER #2	Ground	200,000 GAL	Concrete		A	
ST005	MACS	Ground	200,000 GAL	Concrete		A	
ST001	500 W TANK	Ground	270,000 GAL	Concrete		A	
ST002	LITTLE MISSOURI	Ground	70,000 GAL	Concrete		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	ALDER CREEK CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	LITTLE MISSOURI SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS002	ALDER CREEK SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	600 WEST WELL	Inactive	WL	6	160 GPM		Yes	GW	Other		
WS004	MACS WELL (NORTH)	Active	WL	12	350 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS005	ALDER CREEK #2 WELL	Active	WL	10	420 GPM		Yes	GW	Seasonal		
WS006	PLEASANT VIEW WELL	Inactive	WL				No	GW	Other		
WS007	JESSE CREEK WELL	Active	WL				Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*